

DRAFT/24th November, 2015

The following draft notification, which the Central Government proposes to issue under the Environment (Protection) Act, 1986 (29 of 1986), is hereby published for the information of public likely to be affected thereby; and the notice is hereby given that the said draft notification shall be taken into consideration on or after the expiry of a period of thirty days from the date on which this draft has been made available to public through this website. The comments may be sent to Dr. A.B.Akolkar, MS, CPCB and Mr. R.N.Pankaj, DD (CP): adaba.cpcb@nic.in and rnpankajpcb@gmail.com

[To be published in the Gazette of India, Extraordinary, Part II, Section 3, Sub-section (i)]
GOVERNMENT OF INDIA
MINISTRY OF ENVIRONMENT, FOREST AND CLIMATE CHANGE
NOTIFICATION
New Delhi, -----November, 2015

G.S.R. _____ (E).- In exercise of the powers conferred by sections 6 and 25 of the Environment (Protection) Act, 1986 (29 of 1986), the Central Government hereby makes the following rules further to amend the Environment (Protection) Rules, 1986, namely:

- (1) These rules may be called the Environment (Protection) Amendment Rules, 2015.
- (2) They shall come into force on the date of their publication in the Official Gazette.

2. In the Environment (Protection) Rules, 1986, in Schedule – I

(i) in existing serial number ----- (to be assigned later) for the existing entries and entries relating thereto, the following serial number and entries shall be new, namely:-

STANDARDS FOR SEWAGE TREATMENT PLANTS ALONG WITH TIME FRAME FOR IMPLEMENTATION

Effluent discharged standards for Sewage Treatment Plant are mentioned below:

Sl. No.	Industry	Parameters	Standards for New STPs (Design after notification date)*
	Sewage Treatment Plant	pH	6.5-9.0
		BOD	10
		COD	50
		TSS	20
		NH ₄ -N	5
		N-total	10
		Fecal Coliform (MPN/100ml)	<100

Note:

- (i) All values in mg/l except for pH and Coliform.
- (ii) These standards will be applicable for discharge in water resources as well as for land disposal. The standards for Fecal Coliform may not be applied for use

of treated sewage in industrial purposes.

- * Achievements of Standards for existing STPs within 05 years from date of notification.

[F.No. – Q-15017/2/2008-CPW]

(Dr. Rashid Hasan)
Advisor

Note: - The principal rules were published in the Gazette of India, Extraordinary, Part II, section 3, sub-section (i) vide notification number S.O. 844 (E), 19th November, 1986 and subsequently amended vide notifications numbers S.O. 433 (E), dated 18th April 1987; S.O. 8(E) dated 3rd January, 1989; G.S.R. 176(E) dated 2nd April, 1996; G.S.R. 97 (E), dated the 18th February, 2009; G.S.R. 149 (E), dated the 4th March, 2009; G.S.R. 543(E), dated 22nd July, 2009; G.S.R. 739 (E), dated the 9th September, 2010; G.S.R. 809(E), dated, the 4th October, 2010, G.S.R. 215 (E), dated the 15th March, 2011; G.S.R. 221(E), dated the 18th March, 2011; G.S.R. 354 (E), dated the 2nd May, 2011; G.S.R. 424 (E), dated the 1st June, 2011; G.S.R. 446 (E), dated the 13th June, 2011; G.S.R. 152 (E), dated the 16th March, 2012; G.S.R. 266(E), dated the 30th March, 2012; and G.S.R. 277 (E), dated the 31st March, 2012; and G.S.R. 820(E), dated the 9th November, 2012; G.S.R. 176 (E), dated the 18th March, 2013; G.S.R. 535(E), dated the 7th August, 2013; G.S.R. 771(E), dated the 11th December, 2013; G.S.R. 2(E), dated the 2nd January, 2014; G.S.R. 229 (E), dated the 28th March, 2014; G.S.R. 232(E), dated the 31st March, 2014; G.S.R. 325(E), dated the 07th May, 2014, G.S.R. 612, (E), dated the 25th August 2014 and lastly amended vide notification G.S.R. 789(E), dated 11th November 2014.